



NOTE: ALL RELAY OUTPUT CONTACTS (EXCEPT R1) ARE USER CONFIGURABLE & MAY BE CONFIGURED FOR:

- HEATING STAGES
- COOLING STAGES
- DIGITAL COMPRESSOR
- CONDENSER
- REVERSING VALVE
- HEAT PUMP COMPRESSOR
- PREHEAT
- AUXILIARY HEAT
- HEAT WHEEL
- MORNING WARMUP
- LOW AMBIENT
- ALARM
- OVERRIDE
- OCCUPIED
- ECONOMIZER
- MOD. HEAT EABLE
- MOD. COOL ENABLE
- EMERGENCY HEAT
- REHEAT
- EXHAUST FAN

NOTE: ALL RELAY OUTPUT CONTACTS ARE USER CONFIGURABLE & MAY BE CONFIGURED FOR:

- HEATING STAGES
- COOLING STAGES
- DIGITAL COMPRESSOR
- CONDENSER
- REVERSING VALVE
- HEAT PUMP COMPRESSOR
- PREHEAT
- AUXILIARY HEAT
- HEAT WHEEL
- MORNING WARMUP
- LOW AMBIENT
- ALARM
- OVERRIDE
- OCCUPIED
- ECONOMIZER
- MOD. HEAT EABLE
- MOD. COOL ENABLE
- EMERGENCY HEAT
- REHEAT
- EXHAUST FAN

NOTE: IF THE OE377-26-EV ELECTRONIC EXPANSION VALVE MODULE IS NOT USED THE OE275-03-A SUCTION PRESSURE TRANSDUCER WITH E-BUS ADAPTER KIT WILL BE USED AND CONNECTED TO THE VCB-X CONTROLLER. SEE THE WIRING DETAIL NEXT TO VCB-X CONTROLLER ABOVE.

WattMaster
CONTROLS

TITLE: VCB-X CONTROLLER
ORION CONTROL SYSTEM WIRING

DRAWING NO.: VCB-X-STD-WIRING-1G-P1.DWG

DRAWN BY: B. CREWS
FOR:

REVISION: 02-13-14

CONTRACTOR:

SHEET 1 OF 1

WATTMASTER RESERVES THE RIGHT TO MAKE CHANGES TO PRODUCT SPECIFICATIONS WITHOUT NOTICE.