

At AAON, we are committed to continuously enhancing our products through regular software updates. The release notes below provide an overview of updates, features, and hot fixes introduced in the most recent software versions. This document may not include all changes, especially minor adjustments or security enhancements. Features may vary depending on user settings or environment.

**Note:** AAON software updates are rolled out in phases to monitor performance and adjust as needed before being available to all users. If you are unable to update your software but see new release notes, please check back soon for future availability. It is the responsibility of the building manager to ensure all devices remain current with the latest compatible software version.

## **LF Chiller Refrigeration Module**

### **SS1121**

#### **Software release notes**

Software version 1.12 – Current Version

November 19, 2023

- New feature:
  - Added a “Hot Start Mode” when the Suction Saturation Temperature is above 75 °F, yet the entering water temperature is dropping, which delays the Sight Suction Sat. temperature alarm for 15 minutes.
- Improvements
  - Added an Envelope Protection for the Discharge Sat Temper target, which modulates on the condenser fan
  - Updated the high superheat sensor so it no longer alerts unless EXV is at 100%.
  - Changed the default High Suction Saturation temperature limit to 75 °F.
- Hot fixes
  - Updated the stage timer so the remaining time on Module B is reduced by half whenever Module A is disabled.