

At AAON, we are committed to continuously enhancing our products through regular software updates. The release notes below provide an overview of updates, features, and hot fixes introduced in the most recent software versions. This document may not include all changes, especially minor adjustments or security enhancements. Features may vary depending on user settings or environment.

Note: AAON software updates are rolled out in phases to monitor performance and adjust as needed before being available to all users. If you are unable to update your software but see new release notes, please check back soon for future availability. It is the responsibility of the building manager to ensure all devices remain current with the latest compatible software version.

RSMD-A-B SS3009 Software release notes	
Software version 1.21 – Current Version	September 24, 2025
<ul style="list-style-type: none">• Improvements<ul style="list-style-type: none">○ The hidden diagnostic menus now display the correct screens for analog input voltages.○ Losing the compressor running signal no longer faults the compressor.○ The fault timer automatically clears after an emergency shutdown clears.○ The max signal to the VCCX now holds for 10 seconds before clearing.	