

At AAON, we are committed to continuously enhancing our products through regular software updates. The release notes below provide an overview of updates, features, and hot fixes introduced in the most recent software versions. This document may not include all changes, especially minor adjustments or security enhancements. Features may vary depending on user settings or environment.

Note: AAON software updates are rolled out in phases to monitor performance and adjust as needed before being available to all users. If you are unable to update your software but see new release notes, please check back soon for future availability. It is the responsibility of the building manager to ensure all devices remain current with the latest compatible software version.

STRATUS Unit Manager Software release notes	
Software version 1.1.7 – Current Version	May 18, 2026
<ul style="list-style-type: none"> • Improvements: <ul style="list-style-type: none"> ○ Changed the discharge superheat enable threshold from 50°F to 30°F. ○ Adjusted the OA minimum CFM PID by adding a maximum change limit and reducing the Kp value. ○ Increased the current limit for the 20-ton YAW0961E-7X9 575V compressor from 17.3 to 23.4 FLA. • Hot fixes: <ul style="list-style-type: none"> ○ Fixed an issue with the Airflow Monitor where it would stop polling for Ebtron devices after the initial poll, resulting in a loss of connection. ○ Fixed an issue where the startup admin workflow could be skipped after first attempting to log into a new unit manager. ○ Fixed an issue with the Startup Solenoid, so it only triggers during heating and if the OAT is 20°F upon startup. ○ Fixed an issue where the I/O boards could only upgrade firmware, causing version mismatches when older software was installed over newer versions. 	
Software version 1.1.6	April 20, 2026
<ul style="list-style-type: none"> • Initial release 	